

Date of Study: 03Sep202501Sep2025 / Basic Condition / 19.1 MAF / FTPK -0.0, GARR -2.4, OAHE 2.4
Full Serv -4.5 kcfs 2nd Half / Nav End Date: Dec 01
Elevations & Storages are for Date Shown. Elevations in Local Project Datum (LPD)
Avg Discharge & Energy are Monthly Values

		2025					2026	
		31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck								
Elev	feet	2224.4	2222.6	2222.3	2222.2	2222.1	2221.8	2221.9
Disch	kcfs	8.8	9.0	4.0	4.0	5.0	6.0	6.5
Garrison								
Elev	feet	1832.8	1831.8	1830.3	1828.8	1827.0	1825.7	1825.1
Disch	kcfs	20.3	16.5	14.0	14.0	16.0	16.0	16.0
Oahe								
Elev	feet	1599.4	1598.7	1598.4	1598.5	1598.9	1599.0	1599.6
Disch	kcfs	20.4	20.3	15.2	12.9	13.2	15.7	14.8
Big Bend								
Elev	feet	1421.0	1420.7	1420.4	1420.8	1420.6	1420.7	1420.7
Disch	kcfs	19.6	20.2	15.3	12.5	13.1	15.6	14.8
Fort Randall								
Elev	feet	1355.3	1353.3	1345.0	1337.0	1339.3	1344.8	1349.8
Disch	kcfs	20.0	22.7	25.0	20.5	11.1	10.8	9.4
Gavins Point								
Elev	feet	1207.0	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch	kcfs	22.3	24.4	27.0	23.1	12.5	12.5	12.5
System								
Storage	KAF	50985	50019	48805	47948	47664	47638	47960
Energy	Gwh	3153	685	589	493	454	495	436
Ave Cap	MW		2429	2405	2364	2347	2358	2374

01Sep2025 / Lower Basic Condition / 18.3 MAF / FTPK -0.0, GARR -2.5, OAHE 2.5
Full Serv -4.5 kcfs 2nd Half / Nav End Date: Dec 01

		2025					2026	
		31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck								
Elev	feet	2224.4	2222.4	2222.0	2221.6	2221.3	2220.8	2220.4
Disch	kcfs	8.8	9.0	4.0	4.0	5.0	6.0	6.0
Garrison								
Elev	feet	1832.8	1831.5	1829.9	1828.3	1826.3	1824.9	1823.8
Disch	kcfs	20.3	17.7	13.5	13.5	16.0	16.0	16.0
Oahe								
Elev	feet	1599.4	1598.7	1598.1	1598.0	1598.2	1598.2	1598.5
Disch	kcfs	20.4	21.0	15.8	13.4	13.7	16.2	15.6
Big Bend								
Elev	feet	1421.0	1420.7	1420.4	1420.8	1420.6	1420.7	1420.7
Disch	kcfs	19.6	20.9	15.9	12.9	13.7	16.1	15.6
Fort Randall								
Elev	feet	1355.3	1353.2	1345.0	1337.0	1339.3	1344.7	1349.8
Disch	kcfs	20.0	23.2	25.6	21.0	11.5	11.2	10.0
Gavins Point								
Elev	feet	1207.0	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch	kcfs	22.3	24.4	27.0	23.1	12.5	12.5	12.5
System								
Storage	KAF	50985	49885	48548	47554	47151	46992	47067
Energy	Gwh	3203	706	594	497	462	502	442
Ave Cap	MW		2428	2402	2358	2340	2349	2362

01Sep2025 / Upper Basic Condition / 20.0 MAF / FTPK -0.1, GARR -2.5, OAHE 2.6
Full Serv -4.5 kcfs 2nd Half / Nav End Date: Dec 01

		2025					2026	
		31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck								
Elev	feet	2224.4	2222.8	2223.0	2223.3	2223.4	2223.4	2223.7
Disch	kcfs	8.8	9.0	4.0	4.0	5.5	7.0	7.0
Garrison								
Elev	feet	1832.8	1831.6	1830.3	1829.0	1827.5	1826.8	1826.6
Disch	kcfs	20.3	17.8	14.0	14.0	16.0	16.0	16.0
Oahe								
Elev	feet	1599.4	1599.4	1599.3	1599.6	1600.2	1600.5	1601.5
Disch	kcfs	20.4	19.3	14.5	12.3	12.5	14.8	13.2
Big Bend								
Elev	feet	1421.0	1420.7	1420.4	1420.7	1420.7	1420.7	1420.7
Disch	kcfs	19.6	19.2	14.6	11.9	12.4	14.8	13.2
Fort Randall								
Elev	feet	1355.3	1353.2	1345.0	1337.1	1339.3	1344.8	1349.8
Disch	kcfs	20.0	21.9	24.3	19.8	10.5	10.1	8.3
Gavins Point								
Elev	feet	1207.0	1207.5	1207.5	1207.5	1207.5	1207.5	1206.1
Disch	kcfs	22.3	24.4	27.0	23.1	12.5	12.5	12.5
System								
Storage	KAF	50985	50168	49156	48504	48407	48612	49245
Energy	Gwh	3100	678	576	483	450	493	420
Ave Cap	MW		2431	2409	2371	2356	2371	2391

Date of Study: 03Sep2025		01Sep2025 / Basic Condition / 19.1 MAF / FTPK -0.0, GARR -2.4, OAHE 2.4					
		Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)					
		F-Sum: Sum of Forecasted Values. *: Previous Month's Data					
	2025 *31Aug F-Sum	30Sep	31Oct	30Nov	31Dec	2026 31Jan	28Feb
Fort Peck							
Reach Inflow	1730	170	280	320	300	300	360
Depletion	-136	-124	19	35	-31	-25	-9
Reg Inflow	1866	294	261	285	331	325	369
Evap	272	89	65	64	45	6	3
Release	2057	536	246	238	307	369	361
Stor Change	-463	-330	-50	-17	-21	-50	5
Storage	*12873	12543	12493	12475	12454	12405	12410
Elev feet	*2224.4	2222.6	2222.3	2222.2	2222.1	2221.8	2221.9
Disch kcfs	*8.8	9.0	4.0	4.0	5.0	6.0	6.5
Ave Power MW		122	54	54	68	81	88
Ave Cap MW		206	204	204	204	204	203
Energy GWh	337.1	87.7	40.5	39.2	50.5	60.3	58.9
Garrison							
Reach Inflow	1610	160	300	300	230	260	360
Depletion	-122	-137	43	39	-35	-23	-9
Reg Inflow	3809	832	545	499	564	644	726
Evap	388	115	112	97	65	-2	0
Release	5532	982	861	833	984	984	889
Stor Change	-2111	-265	-428	-432	-485	-338	-163
Storage	*16331	16065	15637	15206	14721	14383	14220
Elev feet	*1832.8	1831.8	1830.3	1828.8	1827.0	1825.7	1825.1
Disch kcfs	*20.3	16.5	14.0	14.0	16.0	16.0	16.0
Ave Power MW		199	169	167	188	186	185
Ave Cap MW		543	539	532	524	517	512
Energy GWh	792.3	143.3	125.4	120.2	140.1	138.7	124.5
Oahe							
Reach Inflow	390	120	75	70	13	12	100
Depletion	-10	-1	-8	-4	-3	-0	7
Reg Inflow	5942	1121	944	907	992	996	981
Evap	400	114	104	93	77	8	4
Release	5511	1209	935	770	809	967	821
Stor Change	31	-202	-96	45	106	22	156
Storage	*16314	16112	16017	16062	16168	16189	16345
Elev feet	*1599.4	1598.7	1598.4	1598.5	1598.9	1599.0	1599.6
Disch kcfs	*20.4	20.3	15.2	12.9	13.2	15.7	14.8
Ave Power MW		242	181	154	157	188	177
Ave Cap MW		667	663	662	664	666	667
Energy GWh	794.8	174.0	134.6	110.7	117.0	139.6	119.0
Big Bend							
Reg Inflow	5512	1207	937	775	805	967	821
Evap	53	21	15	10	5	1	0
Release	5478	1203	942	743	807	962	821
Storage	*1692	1675	1654	1676	1669	1673	1673
Elev feet	*1421.0	1420.7	1420.4	1420.8	1420.6	1420.7	1420.7
Disch kcfs	*19.6	20.2	15.3	12.5	13.1	15.6	14.8
Ave Power MW		94	72	59	62	73	69
Ave Cap MW		507	509	511	510	509	510
Energy GWh	309.8	67.6	53.3	42.2	45.8	54.4	46.5
Fort Randall							
Reach Inflow	140	30	1	-0	15	35	60
Depletion	4	11	-2	-2	-1	-1	-1
Reg Inflow	5616	1212	949	760	810	1003	882
Evap	85	34	30	14	5	1	1
Release	5977	1349	1538	1222	681	666	522
Stor Change	-447	-170	-619	-476	124	336	359
Storage	*3431	3261	2642	2166	2290	2626	2985
Elev feet	*1355.3	1353.3	1345.0	1337.0	1339.3	1344.8	1349.8
Disch kcfs	*20.0	22.7	25.0	20.5	11.1	10.8	9.4
Ave Power MW		200	212	161	86	88	80
Ave Cap MW		379	362	328	317	335	355
Energy GWh	601.6	144.3	157.6	116.2	64.3	65.3	53.9
Gavins Point							
Reach Inflow	720	130	130	120	100	100	140
Depletion	22	-4	4	10	11	1	-1
Reg Inflow	6708	1467	1666	1378	770	768	659
Evap	18	6	6	4	2	0	0
Release	6714	1449	1660	1374	769	769	694
Stor Change	-24	12	-0	0	-0	-1	-35
Storage	*351	363	362	363	362	362	327
Elev feet	*1207.0	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*22.3	24.4	27.0	23.1	12.5	12.5	12.5
Ave Power MW		94	104	90	50	50	49
Ave Cap MW		127	127	127	127	127	126
Energy GWh	316.9	67.8	77.6	64.5	36.9	36.9	33.2
Sioux City							
Reach Inflow	710	230	130	100	75	65	110
Depletion	-3	10	-5	-4	-2	-1	-1
Reg Flow	7451	1662	1795	1509	845	835	805
Reg Flow kcfs		27.9	29.2	25.4	13.7	13.6	14.5
Total							
Reach Inflow	5300	840	916	910	733	772	1130
Depletion	-244	-245	51	74	-61	-50	-13
Evap	1216	379	332	282	199	14	10
Storage	*50985	50019	48805	47948	47664	47638	47960
Ave Power MW		951	792	685	611	666	649
Ave Cap MW		2429	2405	2364	2347	2358	2374
Energy GWh	3152.6	684.7	589.0	493.0	454.5	495.2	436.1
Daily GWh		22.8	19.0	16.4	14.7	16.0	15.6

Date of Study: 03Sep2025		01Sep2025 / Lower Basic Condition / 18.3 MAF / FTPK -0.0, GARR -2.5, OAHE 2.5					
		Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)					
		F-Sum: Sum of Forecasted Values. *: Previous Month's Data					
	2025 *31Aug F-Sum	30Sep	31Oct	30Nov	31Dec	2026 31Jan	28Feb
Fort Peck							
Reach Inflow	1358	128	224	256	240	240	270
Depletion	-220	-132	-5	12	-52	-38	-5
Reg Inflow	1577	260	229	244	292	278	275
Evap	271	89	65	64	45	6	3
Release	2029	536	246	238	307	369	333
Stor Change	-723	-365	-82	-58	-60	-97	-62
Storage	*12873	12509	12427	12369	12309	12212	12150
Elev feet	*2224.4	2222.4	2222.0	2221.6	2221.3	2220.8	2220.4
Disch kcfs	*8.8	9.0	4.0	4.0	5.0	6.0	6.0
Ave Power MW		122	54	54	68	81	80
Ave Cap MW		205	204	203	203	202	202
Energy GWh	331.6	87.6	40.5	39.1	50.3	60.0	54.1
Garrison							
Reach Inflow	1262	120	240	240	184	208	270
Depletion	-168	-148	24	31	-34	-27	-15
Reg Inflow	3484	803	504	447	517	595	618
Evap	386	115	111	97	64	-2	0
Release	5545	1055	830	803	984	984	889
Stor Change	-2447	-367	-438	-453	-531	-387	-271
Storage	*16331	15963	15525	15072	14541	14154	13883
Elev feet	*1832.8	1831.5	1829.9	1828.3	1826.3	1824.9	1823.8
Disch kcfs	*20.3	17.7	13.5	13.5	16.0	16.0	16.0
Ave Power MW		213	162	161	188	186	184
Ave Cap MW		542	537	530	521	513	507
Energy GWh	791.2	153.5	120.7	115.7	139.6	138.0	123.6
Oahe							
Reach Inflow	292	90	56	52	10	9	75
Depletion	-10	-1	-8	-4	-3	-0	7
Reg Inflow	5857	1166	894	860	987	993	956
Evap	398	114	104	92	76	8	4
Release	5725	1248	971	799	840	999	869
Stor Change	-266	-196	-180	-31	71	-13	83
Storage	*16314	16119	15938	15907	15978	15965	16048
Elev feet	*1599.4	1598.7	1598.1	1598.0	1598.2	1598.2	1598.5
Disch kcfs	*20.4	21.0	15.8	13.4	13.7	16.2	15.6
Ave Power MW		249	187	159	162	193	186
Ave Cap MW		668	663	660	661	662	663
Energy GWh	822.5	179.5	139.5	114.6	120.8	143.3	124.9
Big Bend							
Reg Inflow	5726	1245	973	805	835	999	869
Evap	53	21	15	10	5	1	0
Release	5692	1242	978	771	840	993	869
Storage	*1692	1674	1654	1678	1669	1674	1674
Elev feet	*1421.0	1420.7	1420.4	1420.8	1420.6	1420.7	1420.7
Disch kcfs	*19.6	20.9	15.9	12.9	13.7	16.1	15.6
Ave Power MW		97	74	61	64	75	73
Ave Cap MW		507	509	511	510	509	509
Energy GWh	321.7	69.8	55.3	43.7	47.6	56.1	49.2
Fort Randall							
Reach Inflow	105	22	1	-0	11	26	45
Depletion	4	11	-2	-2	-1	-1	-1
Reg Inflow	5794	1243	985	788	838	1026	914
Evap	85	34	30	14	5	1	1
Release	6156	1382	1571	1252	705	691	554
Stor Change	-447	-173	-616	-477	127	333	359
Storage	*3431	3258	2642	2165	2292	2625	2984
Elev feet	*1355.3	1353.2	1345.0	1337.0	1339.3	1344.7	1349.8
Disch kcfs	*20.0	23.2	25.6	21.0	11.5	11.2	10.0
Ave Power MW		205	216	165	89	91	85
Ave Cap MW		379	362	328	317	335	354
Energy GWh	619.0	147.8	160.9	118.9	66.6	67.8	57.1
Gavins Point							
Reach Inflow	540	98	98	90	75	75	105
Depletion	22	-4	4	10	11	1	-1
Reg Inflow	6709	1466	1666	1378	770	768	660
Evap	18	6	6	4	2	0	0
Release	6714	1449	1660	1374	769	769	694
Stor Change	-23	11	-0	1	-0	-1	-34
Storage	*351	362	362	363	362	362	328
Elev feet	*1207.0	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*22.3	24.4	27.0	23.1	12.5	12.5	12.5
Ave Power MW		94	104	90	50	50	49
Ave Cap MW		127	127	127	127	127	126
Energy GWh	316.9	67.8	77.6	64.5	36.9	36.9	33.2
Sioux City							
Reach Inflow	532	172	98	75	56	49	82
Depletion	-3	10	-5	-4	-2	-1	-1
Reg Flow	7274	1605	1762	1484	827	818	777
Reg Flow kcfs		27.0	28.7	24.9	13.4	13.3	14.0
Total							
Reach Inflow	4090	630	716	713	576	607	848
Depletion	-375	-264	8	42	-81	-66	-14
Evap	1211	378	331	281	197	14	10
Storage	*50985	49885	48548	47554	47151	46992	47067
Ave Power MW		981	799	690	621	675	658
Ave Cap MW		2428	2402	2358	2340	2349	2362
Energy GWh	3202.8	706.0	594.4	496.5	461.7	502.1	442.1
Daily GWh		23.5	19.2	16.6	14.9	16.2	15.8

Date of Study: 03Sep2025		01Sep2025 / Upper Basic Condition / 20.0 MAF / FTPK -0.1, GARR -2.5, OAHE 2.6					
		Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)					
		F-Sum: Sum of Forecasted Values. *: Previous Month's Data					
	2025 *31Aug F-Sum	30Sep	31Oct	30Nov	31Dec	2026 31Jan	28Feb
Fort Peck							
Reach Inflow	2076	204	336	384	360	360	432
Depletion	-251	-129	-2	26	-52	-67	-26
Reg Inflow	2327	333	338	358	412	427	458
Evap	273	89	66	65	45	6	3
Release	2177	536	246	238	338	430	389
Stor Change	-123	-291	27	56	28	-10	66
Storage	*12873	12582	12609	12665	12693	12683	12750
Elev feet	*2224.4	2222.8	2223.0	2223.3	2223.4	2223.4	2223.7
Disch kcfs	*8.8	9.0	4.0	4.0	5.5	7.0	7.0
Ave Power MW		122	55	55	75	95	95
Ave Cap MW		206	205	205	205	205	206
Energy GWh	358.2	87.7	40.6	39.4	55.8	70.7	63.9
Garrison							
Reach Inflow	1932	192	360	360	276	312	432
Depletion	-159	-114	50	31	-55	-47	-24
Reg Inflow	4284	841	598	567	657	777	844
Evap	388	115	112	97	65	-2	0
Release	5606	1056	861	833	984	984	889
Stor Change	-1710	-330	-375	-364	-392	-205	-44
Storage	*16331	16001	15626	15262	14870	14665	14620
Elev feet	*1832.8	1831.6	1830.3	1829.0	1827.5	1826.8	1826.6
Disch kcfs	*20.3	17.8	14.0	14.0	16.0	16.0	16.0
Ave Power MW		213	168	167	189	187	187
Ave Cap MW		543	538	532	526	521	519
Energy GWh	804.8	153.7	125.3	120.3	140.4	139.5	125.6
Oahe							
Reach Inflow	532	162	101	94	18	17	140
Depletion	-10	-1	-8	-4	-3	-0	7
Reg Inflow	6159	1237	970	932	997	1001	1021
Evap	405	114	105	94	79	8	4
Release	5182	1146	891	731	769	912	733
Stor Change	571	-24	-26	107	150	81	284
Storage	*16314	16290	16264	16371	16521	16601	16886
Elev feet	*1599.4	1599.4	1599.3	1599.6	1600.2	1600.5	1601.5
Disch kcfs	*20.4	19.3	14.5	12.3	12.5	14.8	13.2
Ave Power MW		230	173	147	151	179	160
Ave Cap MW		669	667	667	671	673	676
Energy GWh	753.8	165.7	129.0	106.0	112.2	133.2	107.7
Big Bend							
Reg Inflow	5183	1145	893	736	764	912	733
Evap	53	21	15	10	5	1	0
Release	5149	1141	897	707	764	907	733
Storage	*1692	1674	1655	1674	1670	1674	1674
Elev feet	*1421.0	1420.7	1420.4	1420.7	1420.7	1420.7	1420.7
Disch kcfs	*19.6	19.2	14.6	11.9	12.4	14.8	13.2
Ave Power MW		89	68	56	58	69	62
Ave Cap MW		508	510	511	511	510	510
Energy GWh	291.5	64.3	50.8	40.2	43.3	51.4	41.6
Fort Randall							
Reach Inflow	194	40	1	-1	20	49	84
Depletion	4	11	-2	-2	-1	-1	-1
Reg Inflow	5342	1161	904	723	772	963	819
Evap	85	34	30	14	5	1	1
Release	5702	1300	1494	1180	645	624	459
Stor Change	-445	-172	-619	-471	122	337	359
Storage	*3431	3259	2640	2169	2291	2628	2987
Elev feet	*1355.3	1353.2	1345.0	1337.1	1339.3	1344.8	1349.8
Disch kcfs	*20.0	21.9	24.3	19.8	10.5	10.1	8.3
Ave Power MW		193	206	156	82	82	71
Ave Cap MW		379	362	328	317	335	355
Energy GWh	574.5	139.2	153.2	112.4	61.0	61.2	47.4
Gavins Point							
Reach Inflow	984	176	176	162	135	140	196
Depletion	22	-4	4	10	11	1	-1
Reg Inflow	6709	1466	1666	1378	770	768	662
Evap	18	6	6	4	2	0	0
Release	6714	1449	1660	1374	769	769	694
Stor Change	-22	11	-0	1	-1	-1	-33
Storage	*351	362	362	363	362	361	328
Elev feet	*1207.0	1207.5	1207.5	1207.5	1207.5	1207.5	1206.1
Disch kcfs	*22.3	24.4	27.0	23.1	12.5	12.5	12.5
Ave Power MW		94	104	90	50	50	49
Ave Cap MW		127	127	127	127	127	126
Energy GWh	316.9	67.8	77.6	64.5	36.9	36.9	33.2
Sioux City							
Reach Inflow	967	310	176	135	101	91	154
Depletion	-3	10	-5	-4	-2	-1	-1
Reg Flow	7708	1743	1840	1544	872	861	849
Reg Flow kcfs		29.3	29.9	26.0	14.2	14.0	15.3
Total							
Reach Inflow	6686	1084	1149	1135	910	969	1438
Depletion	-396	-228	36	57	-102	-115	-45
Evap	1223	379	334	284	201	15	10
Storage	*50985	50168	49156	48504	48407	48612	49245
Ave Power MW		942	775	671	604	663	624
Ave Cap MW		2431	2409	2371	2356	2371	2391
Energy GWh	3099.7	678.4	576.5	482.8	449.5	493.0	419.5
Daily GWh		22.6	18.6	16.1	14.5	15.9	15.0