

Date of Study: 04Aug2026

01Aug2026 / Basic Condition / 15.4 MAF / FTPK -0.1, GARR -1.1, OAHE 1.2
Min Serv 2nd Half / Nav End Date: Nov 15
Elevations & Storages are for Date Shown. Elevations in Local Project Datum (LPD)
Avg Discharge & Energy are Monthly Values

		2026						2027	
		31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck									
	Elev feet	2223.9	2223.3	2222.0	2221.2	2220.3	2218.3	2216.9	2216.0
	Disch kcfs	6.8	7.0	7.0	5.0	5.0	9.0	9.5	9.5
Garrison									
	Elev feet	1827.5	1826.3	1825.3	1824.1	1822.6	1821.8	1821.5	1821.7
	Disch kcfs	18.0	17.2	15.0	13.0	13.0	14.0	15.0	15.0
Oahe									
	Elev feet	1596.1	1593.7	1591.5	1591.7	1593.0	1593.0	1592.9	1593.3
	Disch kcfs	23.8	27.3	24.7	11.7	7.3	12.9	15.7	14.5
Big Bend									
	Elev feet	1420.8	1420.8	1420.6	1420.7	1420.8	1420.5	1421.0	1421.0
	Disch kcfs	24.4	26.9	24.6	11.5	7.1	13.0	15.3	14.5
Fort Randall									
	Elev feet	1355.1	1354.9	1353.3	1341.2	1337.1	1339.4	1344.6	1349.5
	Disch kcfs	24.0	26.9	26.6	25.4	10.7	11.1	10.8	9.3
Gavins Point									
	Elev feet	1206.6	1206.5	1207.5	1207.5	1207.6	1207.5	1207.5	1206.0
	Disch kcfs	25.7	28.5	28.3	27.3	13.2	12.5	12.5	12.5
System									
	Storage KAF	48483	47426	46252	44960	44538	44082	44060	44376
	Energy Gwh	3811	802	722	537	338	464	507	441
	Ave Cap MW		2381	2362	2335	2293	2287	2299	2317

01Aug2026 / Lower Basic Condition / 14.6 MAF / FTPK -0.0, GARR -0.9, OAHE 0.9

Min Serv 2nd Half / Nav End Date: Nov 15

		2026						2027	
		31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck									
	Elev feet	2223.9	2223.1	2221.7	2220.7	2219.8	2217.5	2215.9	2214.5
	Disch kcfs	6.8	7.0	7.0	5.0	5.0	9.5	9.5	9.5
Garrison									
	Elev feet	1827.5	1826.2	1825.1	1823.7	1822.1	1821.2	1820.8	1820.6
	Disch kcfs	18.0	17.3	15.0	13.0	13.0	14.0	15.0	15.0
Oahe									
	Elev feet	1596.1	1593.4	1590.9	1590.9	1592.1	1592.0	1591.7	1591.8
	Disch kcfs	23.8	28.4	25.3	12.2	7.6	13.6	16.2	15.5
Big Bend									
	Elev feet	1420.8	1420.9	1420.6	1420.7	1420.5	1420.5	1421.0	1421.0
	Disch kcfs	24.4	27.9	25.2	12.0	7.5	13.6	15.8	15.5
Fort Randall									
	Elev feet	1355.1	1354.9	1353.3	1341.2	1337.1	1339.4	1344.5	1349.6
	Disch kcfs	24.0	27.7	27.1	25.9	11.2	11.5	11.2	10.0
Gavins Point									
	Elev feet	1206.6	1206.5	1207.5	1207.5	1207.6	1207.5	1207.5	1206.0
	Disch kcfs	25.7	28.5	28.3	27.3	13.2	12.5	12.5	12.5
System									
	Storage KAF	48483	47282	45977	44577	44046	43526	43393	43482
	Energy Gwh	3879	818	731	545	343	477	513	452
	Ave Cap MW		2379	2358	2329	2285	2278	2289	2304

01Aug2026 / Upper Basic Condition / 16.4 MAF / FTPK -0.0, GARR -1.1, OAHE 1.2

Min Serv 2nd Half / Nav End Date: Nov 15

		2026						2027	
		31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck									
	Elev feet	2223.9	2223.6	2222.6	2221.9	2221.3	2219.7	2218.8	2218.3
	Disch kcfs	6.8	7.0	7.0	5.5	5.5	9.5	9.5	9.5
Garrison									
	Elev feet	1827.5	1826.3	1825.5	1824.6	1823.5	1823.0	1823.0	1823.6
	Disch kcfs	18.0	17.3	15.0	13.0	13.0	14.0	15.0	15.0
Oahe									
	Elev feet	1596.1	1594.1	1592.2	1592.7	1594.1	1594.3	1594.4	1595.3
	Disch kcfs	23.8	26.4	23.8	11.2	6.9	12.4	14.9	13.0
Big Bend									
	Elev feet	1420.8	1420.9	1420.6	1420.7	1420.7	1420.5	1421.0	1421.0
	Disch kcfs	24.4	26.0	23.6	11.0	6.7	12.4	14.4	13.0
Fort Randall									
	Elev feet	1355.1	1354.9	1353.4	1341.4	1337.1	1339.4	1344.6	1349.5
	Disch kcfs	24.0	26.1	26.0	24.8	10.5	10.5	10.1	8.3
Gavins Point									
	Elev feet	1206.6	1206.5	1207.5	1207.5	1207.6	1207.5	1207.4	1206.0
	Disch kcfs	25.7	28.5	28.3	27.3	13.8	12.5	12.5	12.5
System									
	Storage KAF	48483	47593	46582	45468	45210	44958	45163	45770
	Energy Gwh	3749	787	709	534	339	461	496	423
	Ave Cap MW		2383	2367	2342	2303	2300	2316	2338

Date of Study: 04Aug2026		01Aug2026 / Basic Condition / 15.4 MAF / FTPK -0.1, GARR -1.1, OAHE 1.2 Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD) F-Sum: Sum of Forecasted Values. *: Previous Month's Data						
	2026 *31Jul F-Sum	31Aug	30Sep	31Oct	30Nov	31Dec	2027 31Jan	28Feb
Fort Peck								
Reach Inflow	1615	100	140	220	240	240	310	365
Depletion	-415	-293	-133	9	33	6	-38	1
Reg Inflow	2030	393	273	211	207	234	347	364
Evap	345	76	88	65	63	44	6	3
Release	3116	430	417	307	298	552	584	528
Stor Change	-1431	-114	-231	-161	-153	-363	-242	-166
Storage	*12787	12673	12442	12281	12127	11765	11522	11356
Elev feet	*2223.9	2223.3	2222.0	2221.2	2220.3	2218.3	2216.9	2216.0
Disch kcfs	*6.8	7.0	7.0	5.0	5.0	9.0	9.5	9.5
Ave Power MW		95	95	68	67	119	124	124
Ave Cap MW		206	204	203	202	200	198	196
Energy GWh	501.4	70.5	68.2	50.3	48.4	88.4	92.5	83.0
Garrison								
Reach Inflow	1710	150	200	300	250	190	260	360
Depletion	-266	-248	-126	49	54	-5	2	8
Reg Inflow	5070	827	743	575	493	715	837	879
Evap	443	84	107	103	90	60	-1	0
Release	6143	1059	893	799	774	863	922	833
Stor Change	-1515	-315	-256	-327	-370	-208	-84	46
Storage	*14847	14532	14275	13948	13578	13369	13286	13332
Elev feet	*1827.5	1826.3	1825.3	1824.1	1822.6	1821.8	1821.5	1821.7
Disch kcfs	*18.0	17.2	15.0	13.0	13.0	14.0	15.0	15.0
Ave Power MW		201	174	151	149	160	170	169
Ave Cap MW		519	514	509	503	498	495	494
Energy GWh	853.4	149.6	125.5	112.1	107.5	118.7	126.1	113.9
Oahe								
Reach Inflow	442	80	100	70	65	15	12	100
Depletion	1	11	-1	-8	-4	-3	-0	7
Reg Inflow	6594	1132	1008	877	843	873	935	926
Evap	436	70	103	95	86	71	7	4
Release	6877	1680	1470	721	437	794	968	806
Stor Change	-719	-618	-565	62	320	8	-40	116
Storage	*15422	14803	14238	14300	14620	14628	14587	14703
Elev feet	*1596.1	1593.7	1591.5	1591.7	1593.0	1593.0	1592.9	1593.3
Disch kcfs	*23.8	27.3	24.7	11.7	7.3	12.9	15.7	14.5
Ave Power MW		312	277	132	84	148	179	166
Ave Cap MW		645	634	628	632	635	635	636
Energy GWh	945.7	232.1	199.7	98.5	60.6	109.9	133.4	111.4
Big Bend								
Reg Inflow	6884	1681	1472	725	437	794	968	807
Evap	77	24	21	15	10	5	1	0
Release	6795	1654	1463	707	421	802	941	806
Storage	*1678	1681	1668	1671	1676	1663	1690	1690
Elev feet	*1420.8	1420.8	1420.6	1420.7	1420.8	1420.5	1421.0	1421.0
Disch kcfs	*24.4	26.9	24.6	11.5	7.1	13.0	15.3	14.5
Ave Power MW		124	114	54	34	61	72	68
Ave Cap MW		504	505	511	513	511	509	510
Energy GWh	382.7	92.2	81.8	40.1	24.1	45.5	53.3	45.7
Fort Randall								
Reach Inflow	187	40	35	1	1	10	35	65
Depletion	37	33	11	-2	-2	-1	-1	-1
Reg Inflow	6966	1665	1487	725	420	810	986	873
Evap	110	28	33	29	13	6	1	1
Release	7306	1655	1586	1565	634	682	665	519
Stor Change	-450	-18	-132	-868	-226	122	319	352
Storage	*3417	3399	3267	2399	2173	2295	2614	2967
Elev feet	*1355.1	1354.9	1353.3	1341.2	1337.1	1339.4	1344.6	1349.5
Disch kcfs	*24.0	26.9	26.6	25.4	10.7	11.1	10.8	9.3
Ave Power MW		238	234	212	83	87	88	80
Ave Cap MW		381	379	356	316	317	335	354
Energy GWh	746.7	177.2	168.8	157.9	59.7	64.5	65.2	53.5
Gavins Point								
Reach Inflow	830	130	120	120	120	100	100	140
Depletion	47	25	-4	4	10	11	1	-1
Reg Inflow	8142	1754	1714	1684	794	768	768	661
Evap	23	5	6	6	4	2	0	0
Release	8133	1752	1684	1679	787	768	769	694
Stor Change	-14	-4	24	-0	2	-2	-1	-34
Storage	*342	338	362	361	364	362	361	328
Elev feet	*1206.6	1206.5	1207.5	1207.5	1207.6	1207.5	1207.5	1206.0
Disch kcfs	*25.7	28.5	28.3	27.3	13.2	12.5	12.5	12.5
Ave Power MW		108	108	105	52	49	50	49
Ave Cap MW		126	127	127	127	127	127	126
Energy GWh	380.8	80.1	78.0	78.4	37.3	36.8	36.9	33.2
Sioux City								
Reach Inflow	625	120	100	90	80	65	60	110
Depletion	68	71	10	-5	-4	-2	-1	-1
Reg Flow	8724	1800	1775	1776	912	827	830	805
Reg Flow kcfs		29.3	29.8	28.9	15.3	13.4	13.5	14.5
Total								
Reach Inflow	5409	620	695	801	756	620	777	1140
Depletion	-528	-401	-244	46	87	7	-37	14
Evap	1434	287	359	313	265	187	14	9
Storage	*48483	47426	46252	44960	44538	44082	44060	44376
Ave Power MW		1078	1003	722	469	623	682	656
Ave Cap MW		2381	2362	2335	2293	2287	2299	2317
Energy GWh	3810.7	801.7	722.0	537.3	337.6	463.7	507.4	440.8
Daily GWh		25.9	24.1	17.3	11.3	15.0	16.4	15.7

Date of Study: 04Aug2026		01Aug2026 / Lower Basic Condition / 14.6 MAF / FTPK -0.0, GARR -0.9, OAHE 0.9						
		Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)						
		F-Sum: Sum of Forecasted Values. *: Previous Month's Data						
	2026 *31Jul F-Sum	31Aug	30Sep	31Oct	30Nov	31Dec	2027 31Jan	28Feb
Fort Peck								
Reach Inflow	1257	70	105	176	192	192	248	274
Depletion	-558	-295	-136	-12	3	-36	-61	-21
Reg Inflow	1815	365	241	188	189	228	309	295
Evap	344	76	88	65	63	44	6	3
Release	3148	430	417	307	298	584	584	528
Stor Change	-1676	-142	-263	-184	-172	-399	-281	-236
Storage	*12787	12645	12382	12198	12026	11627	11346	11110
Elev feet	*2223.9	2223.1	2221.7	2220.7	2219.8	2217.5	2215.9	2214.5
Disch kcfs	*6.8	7.0	7.0	5.0	5.0	9.5	9.5	9.5
Ave Power MW		95	95	67	67	125	124	123
Ave Cap MW		206	204	203	201	199	197	195
Energy GWh	504.7	70.5	68.1	50.2	48.3	93.1	92.1	82.4
Garrison								
Reach Inflow	1325	105	150	240	200	152	208	270
Depletion	-360	-267	-139	27	48	-17	-10	-3
Reg Inflow	4811	801	705	537	450	716	802	800
Evap	441	83	106	103	90	60	-1	0
Release	6145	1061	893	799	774	863	922	833
Stor Change	-1775	-343	-294	-365	-414	-207	-119	-33
Storage	*14847	14504	14210	13845	13431	13224	13105	13072
Elev feet	*1827.5	1826.2	1825.1	1823.7	1822.1	1821.2	1820.8	1820.6
Disch kcfs	*18.0	17.3	15.0	13.0	13.0	14.0	15.0	15.0
Ave Power MW		201	174	150	149	159	169	168
Ave Cap MW		519	513	508	501	495	492	490
Energy GWh	851.0	149.8	125.4	111.8	107.1	118.2	125.5	113.1
Oahe								
Reach Inflow	324	52	75	52	49	11	9	75
Depletion	1	11	-1	-8	-4	-3	-0	7
Reg Inflow	6478	1106	983	860	827	870	932	901
Evap	433	70	103	94	85	70	7	4
Release	7151	1743	1506	752	450	839	999	862
Stor Change	-1107	-708	-626	14	292	-40	-74	35
Storage	*15422	14714	14088	14102	14393	14354	14280	14315
Elev feet	*1596.1	1593.4	1590.9	1590.9	1592.1	1592.0	1591.7	1591.8
Disch kcfs	*23.8	28.4	25.3	12.2	7.6	13.6	16.2	15.5
Ave Power MW		323	283	137	86	155	183	175
Ave Cap MW		645	631	624	628	630	629	629
Energy GWh	976.5	240.2	203.6	102.0	61.9	115.0	136.2	117.5
Big Bend								
Reg Inflow	7158	1744	1508	756	450	839	999	862
Evap	77	24	21	15	10	5	1	0
Release	7069	1717	1500	738	447	834	972	861
Storage	*1678	1682	1668	1671	1663	1663	1689	1690
Elev feet	*1420.8	1420.9	1420.6	1420.7	1420.5	1420.5	1421.0	1421.0
Disch kcfs	*24.4	27.9	25.2	12.0	7.5	13.6	15.8	15.5
Ave Power MW		128	116	56	36	64	74	73
Ave Cap MW		503	505	511	513	510	509	509
Energy GWh	397.7	95.5	83.8	41.9	25.6	47.3	55.0	48.7
Fort Randall								
Reach Inflow	136	26	26	1	1	8	26	49
Depletion	37	33	11	-2	-2	-1	-1	-1
Reg Inflow	7188	1713	1516	756	446	839	1008	911
Evap	110	27	33	29	13	6	1	1
Release	7527	1703	1616	1595	663	707	691	553
Stor Change	-449	-17	-133	-867	-230	126	315	357
Storage	*3417	3399	3267	2400	2169	2296	2611	2968
Elev feet	*1355.1	1354.9	1353.3	1341.2	1337.1	1339.4	1344.5	1349.6
Disch kcfs	*24.0	27.7	27.1	25.9	11.2	11.5	11.2	10.0
Ave Power MW		245	239	216	87	90	91	85
Ave Cap MW		381	379	356	315	317	335	354
Energy GWh	768.5	182.0	171.9	160.8	62.4	66.7	67.7	57.0
Gavins Point								
Reach Inflow	610	84	90	90	90	75	75	105
Depletion	47	25	-4	4	10	11	1	-1
Reg Inflow	8141	1754	1714	1684	794	767	769	659
Evap	23	5	6	6	4	2	0	0
Release	8133	1752	1684	1679	787	768	769	694
Stor Change	-15	-4	24	-1	3	-3	0	-35
Storage	*342	338	362	361	364	362	362	327
Elev feet	*1206.6	1206.5	1207.5	1207.5	1207.6	1207.5	1207.5	1206.0
Disch kcfs	*25.7	28.5	28.3	27.3	13.2	12.5	12.5	12.5
Ave Power MW		108	108	105	52	49	50	49
Ave Cap MW		126	127	127	127	127	127	126
Energy GWh	380.8	80.1	78.0	78.4	37.3	36.8	36.9	33.2
Sioux City								
Reach Inflow	457	78	75	68	60	49	45	82
Depletion	68	71	10	-5	-4	-2	-1	-1
Reg Flow	8556	1758	1750	1754	892	810	815	777
Reg Flow kcfs		28.6	29.4	28.5	15.0	13.2	13.2	14.0
Total								
Reach Inflow	4108	416	521	627	592	486	611	855
Depletion	-765	-422	-259	4	51	-48	-72	-18
Evap	1428	287	358	311	264	186	13	9
Storage	*48483	47282	45977	44577	44046	43526	43393	43482
Ave Power MW		1100	1015	733	476	641	690	673
Ave Cap MW		2379	2358	2329	2285	2278	2289	2304
Energy GWh	3879.2	818.3	730.8	545.1	342.6	477.0	513.3	452.0
Daily GWh		26.4	24.4	17.6	11.4	15.4	16.6	16.1

Date of Study: 04Aug2026		01Aug2026 / Upper Basic Condition / 16.4 MAF / FTPK -0.0, GARR -1.1, OAHE 1.2 Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD) F-Sum: Sum of Forecasted Values. *: Previous Month's Data						
	2026 *31Jul F-Sum	31Aug	30Sep	31Oct	30Nov	31Dec	2027 31Jan	28Feb
Fort Peck								
Reach Inflow	1948	130	168	264	288	288	372	438
Depletion	-588	-323	-145	-13	9	-48	-59	-9
Reg Inflow	2536	453	313	277	279	336	431	447
Evap	347	76	88	65	64	44	6	3
Release	3208	430	417	338	327	584	584	528
Stor Change	-1019	-53	-192	-126	-112	-293	-159	-83
Storage	*12787	12734	12542	12415	12303	12010	11851	11768
Elev feet	*2223.9	2223.6	2222.6	2221.9	2221.3	2219.7	2218.8	2218.3
Disch kcfs	*6.8	7.0	7.0	5.5	5.5	9.5	9.5	9.5
Ave Power MW		95	95	75	74	126	125	125
Ave Cap MW		206	205	204	203	202	200	199
Energy GWh	519.3	70.6	68.4	55.5	53.5	94.0	93.4	84.0
Garrison								
Reach Inflow	2067	195	240	360	300	228	312	432
Depletion	-302	-219	-122	57	42	-30	-23	-8
Reg Inflow	5556	843	779	654	586	808	919	967
Evap	445	84	107	104	91	61	-1	0
Release	6145	1061	893	799	774	863	922	833
Stor Change	-1034	-301	-221	-249	-279	-116	-2	134
Storage	*14847	14546	14325	14075	13797	13681	13679	13813
Elev feet	*1827.5	1826.3	1825.5	1824.6	1823.5	1823.0	1823.0	1823.6
Disch kcfs	*18.0	17.3	15.0	13.0	13.0	14.0	15.0	15.0
Ave Power MW		201	174	151	150	161	171	171
Ave Cap MW		519	514	511	506	502	501	502
Energy GWh	858.0	149.9	125.6	112.3	108.0	119.5	127.4	115.2
Oahe								
Reach Inflow	602	108	135	94	88	20	17	140
Depletion	1	11	-1	-8	-4	-3	-0	7
Reg Inflow	6757	1162	1043	902	866	879	940	966
Evap	440	71	104	96	87	72	7	4
Release	6533	1621	1414	690	410	761	913	723
Stor Change	-216	-530	-475	116	370	46	19	239
Storage	*15422	14891	14416	14532	14902	14948	14967	15205
Elev feet	*1596.1	1594.1	1592.2	1592.7	1594.1	1594.3	1594.4	1595.3
Disch kcfs	*23.8	26.4	23.8	11.2	6.9	12.4	14.9	13.0
Ave Power MW		302	269	128	79	143	171	151
Ave Cap MW		646	636	632	637	641	642	645
Energy GWh	905.3	224.6	193.3	95.0	57.2	106.3	127.4	101.5
Big Bend								
Reg Inflow	6540	1623	1416	695	409	760	914	724
Evap	77	24	21	15	10	5	1	0
Release	6451	1596	1407	677	399	763	887	723
Storage	*1678	1681	1668	1670	1671	1663	1690	1690
Elev feet	*1420.8	1420.9	1420.6	1420.7	1420.7	1420.5	1421.0	1421.0
Disch kcfs	*24.4	26.0	23.6	11.0	6.7	12.4	14.4	13.0
Ave Power MW		120	109	52	32	58	68	61
Ave Cap MW		504	506	511	514	511	510	511
Energy GWh	363.7	89.0	78.8	38.5	22.8	43.3	50.2	41.1
Fort Randall								
Reach Inflow	257	54	47	1	1	14	49	91
Depletion	37	33	11	-2	-2	-1	-1	-1
Reg Inflow	6694	1621	1443	697	397	774	945	816
Evap	111	28	33	29	13	6	1	1
Release	7034	1607	1544	1522	627	646	624	464
Stor Change	-451	-13	-134	-854	-242	122	320	351
Storage	*3417	3403	3269	2415	2173	2294	2615	2966
Elev feet	*1355.1	1354.9	1353.4	1341.4	1337.1	1339.4	1344.6	1349.5
Disch kcfs	*24.0	26.1	26.0	24.8	10.5	10.5	10.1	8.3
Ave Power MW		232	228	207	82	82	82	71
Ave Cap MW		381	379	357	316	317	335	354
Energy GWh	720.1	172.2	164.5	154.0	59.1	61.2	61.2	47.9
Gavins Point								
Reach Inflow	1132	176	162	162	162	135	140	196
Depletion	47	25	-4	4	10	11	1	-1
Reg Inflow	8176	1754	1713	1684	828	767	768	661
Evap	23	5	6	6	4	2	0	0
Release	8167	1752	1684	1679	822	768	769	694
Stor Change	-14	-3	23	-0	3	-2	-1	-33
Storage	*342	338	362	361	364	362	361	328
Elev feet	*1206.6	1206.5	1207.5	1207.5	1207.6	1207.5	1207.4	1206.0
Disch kcfs	*25.7	28.5	28.3	27.3	13.8	12.5	12.5	12.5
Ave Power MW		108	108	105	54	49	50	49
Ave Cap MW		126	127	127	127	127	127	126
Energy GWh	382.4	80.1	78.0	78.4	38.9	36.8	36.9	33.2
Sioux City								
Reach Inflow	852	162	135	122	108	88	84	154
Depletion	68	71	10	-5	-4	-2	-1	-1
Reg Flow	8985	1842	1810	1808	974	849	854	849
Reg Flow kcfs		30.0	30.4	29.4	16.4	13.8	13.9	15.3
Total								
Reach Inflow	6860	824	887	1003	947	772	974	1451
Depletion	-737	-402	-251	33	51	-72	-83	-12
Evap	1442	287	360	314	268	189	14	9
Storage	*48483	47593	46582	45468	45210	44958	45163	45770
Ave Power MW		1057	984	717	471	620	667	629
Ave Cap MW		2383	2367	2342	2303	2300	2316	2338
Energy GWh	3748.8	786.5	708.6	533.7	339.4	461.1	496.4	422.9
Daily GWh		25.4	23.6	17.2	11.3	14.9	16.0	15.1